

(915) 590-8500 • Fax (915) 590-8510

To: SIEMENS E&A

Attn: Fax:

NOTES:

1. SIZE: 6.25" X 8.75" .125 rcr

2. MATERIAL: Semi-Gloss Paper w/ Permanent Adhesive

3. INK COLOR: Black, PMS 185 Red

6.25"

# **SIEMENS**

Cat. No. DTGNF324R Non-Fusible General Duty Double Throw Safety Switch Type VB II 240 Volts AC (V~)Maximum 250 Volts DC (V...) Maximum 200 Amps Maximum **NEMA Type 3R** Rainproof

Horsepower Ratings	240 VAC¹ 1Ø	240 VAC 3Ø	250 VDC <sup>1</sup>
Max. HP	15	60	40

Suitable for use as Service Equipment when used with ground bar kit HG61234 on 3 phase, 3 wire systems or when used with HNC264

Manually-operated switch suitable for use in accordance with Article 702 of the National Electrical Code, ANSI/NFPA 70.

Fuse and Short Circuit Information

This switch is suitable for use on a circuit capable of delivering not more than 100,000 amperes, RMS symmetrical, 240 volts maximum when protected by class J, R or T fuses rated 200 amperes maximum.

Danger - Unless Class J, R or T fuses are used to protect this switch, it may present a risk of fire and injury to persons if installed on circuits capable of delivering more than 10,000 amperes, RMS symmetrical.

This switch is suitable for use on a circuit capable of delivering not more than 10,000 amperes, RMS symmetrical, 240 volts maximum, when protected by Class K fuses, Class H fuses or a UL Listed Circuit Breaker rated for 10,000 amperes, RMS symmetrical, 240 volts maximum. This switch is suitable for use on a circuit capable of delivering not more than 10,000 amperes, 250 volts DC maximum, when protected by fuses marked with an interrupting rating of 10,000 amperes, 250 volts DC.

Danger – Unless fuses marked for an interrupting rating of 10,000 amperes at 250 volts DC are used to protect this switch, this switch may present a risk of fire and injury to persons if installed on circuits capable of delivering more than 10,000 amperes.



8.75"

### **DANGER**

### Hazardous voltage. Will cause death or serious injury.

• Disconnect and lock out power supplying this switch before working on this switch.

- Turn off switch before removing or installing fuses if so equipped.
  Always use a properly rated voltage sensing device on all fuse clips (Fusible) or all
- load side terminals (Non-Fusible) to confirm switch is off. • Close or replace cover before turning power on.

**Terminal & Wire Information** 

## **USE 75°C COPPER OR ALUMINUM WIRE**

Terminal & Wire Information				
Description	Wire Range	Wire Tightening Torque <sup>5</sup>	Lug Mounting Torque⁵	
Line, Load & Main Neutral	6 AWG-250 kcmil	275 lb-ins.	135 lb-ins.	
Service Ground	14-1/0 AWG	35 lb-ins. 14-10 AWG / 40 lb-ins. 8 AWG 45 lb-ins. 6-4 AWG / 50 lb-ins. 3-1/0 AWG	80 lb-ins.	

Inspection record number:

Accessories					
Aux. Switch (1NO - 1NC)	HA161234	Neutral	HNC264	Hub Kits	HS150 (1 1/2") HS200 (2")
Aux. Switch (2NO - 2NC)	HA261234	Ground Lug Kit (Wire Range 14-4 AWG)	HG61234		HS250 (2 1/2")

# **Replacement Parts**

Line Base	HNB64	Wire Grip Kit (AL)	HL64	Handle / Handle Guard	HHD61234
Load Base		Mechanism		Door	

Protected by one or more of the following US Patents: 6,134,979, 5,945,650, 5,990,439.

<sup>1</sup> Use outer two poles.

<sup>&</sup>lt;sup>5</sup> When tightening or replacing connectors, refer to lug mounting torque in Terminal & Wire Information Table.



Siemens Energy & Automation, Inc. http://www.sea.siemens.com/power Assembled in Mexico

Pc. No. 506170G03 1203

> R .125" X4

	OK to print
	OK to Print with corrections as marked
	Make corrections, resubmit corrected proof
Job v	vill not be printed unless approved

Artw Proo

by customer.					
rtwork By:	Date:	AUTHORIZED BY	DATE	PART NUMBER	REV
roofer:	Date:		06/10/08	506170G03	23P