

(915) 590-8500 • Fax (915) 590-8510

To: SIEMENS

Attn: Fax:

NOTES:

1. SIZE: 6.125" X 11.375" rcr .125"

2. MATERIAL: Semi-Gloss Paper w/ Permanent Adhesive

3. INK COLOR: Black, PMS 185 Red

6.125" —

.125" rcr X4

SIEMENS

Cat. No. DTNF323R 100 Amps Maximum **NEMA Type 3R**

Non-Fusible Heavy Duty Double Throw Safety Switch Type VB II 240 Volts AC (V~) Maximum 250 Volts DC (V...) Maximum Rainproof

240 VAC 240 VAC 3Ø 250 VDC1 Horsepower Ratings Max. HP

Suitable for use as Service Equipment when used with ground bar kit **HG61234** on 3 phase, 3 wire systems or when used with HN263 neutral kit on 1 phase, 3 wire or 3 phase, 4 wire systems.

Manually-operated switch suitable for use in accordance with Article 702 of the National Electrical Code, ANSI/NFPA 70.

Fuse and Short Circuit Information

This switch is suitable for use on a circuit capable of delivering not more than 200,000 amperes, RMS symmetrical, 240 volts maximum when protected by class J, R or T fuses rated 100 amperes maximum.

Danger – Unless Class J, R or T fuses are used to protect this switch, it may present a risk of fire and injury to persons if installed on circuits capable of delivering more than 10,000 amperes, RMS symmetrical.

This switch is suitable for use on a circuit capable of delivering not more than 10,000 amperes, RMS symmetrical, 240 volts maximum, when protected by Class K fuses, Class H fuses or a UL Listed Circuit Breaker rated for 10,000 amperes, RMS symmetrical, **240** volts maximum.

This switch is suitable for use on a circuit capable of delivering not more than 10,000 amperes, **250** volts DC maximum, when protected by fuses marked with an interrupting rating of 10,000 amperes, **250** volts DC.

Danger - Unless fuses marked for an interrupting rating of 10,000 amperes at 250 volts DC are used to protect this switch, this switch may present a risk of fire and injury to persons if installed on circuits capable of delivering more than 10,000 amperes.



Terminal & Wire Information

DANGER

Hazardous voltage. Will cause death or serious injury.

Disconnect and lock out power supplying this switch before working on this switch.
Turn off switch before removing or installing fuses if so equipped.
Always use a properly rated voltage sensing device on all fuse clips (Fusible) or all

load side terminals (Non-Fusible) to confirm switch is off.

• Close or replace cover before turning power on.

11.375"

USE 75°C COPPER OR ALUMINUM WIRE

Terminal & Wire Information						
Description	Wire Tightening Torque⁵	Lug Mounting Torque ⁵				
Line, Load & Main Neutral	14-1/0 AWG	35 lb-ins. 14-10AWG / 40 lb-ins. 8 AWG 45 lb-ins. 6-4 AWG / 50 lb-ins. 3-1/0 AWG	80 lb-ins.			
Service Ground	14-4 AWG	35 lb-ins. 14-10AWG / 40 lb-ins. 8 AWG 45 lb-ins. 6-4 AWG	24 lb-ins.			

Inspection record number:

UL Listed Compression Lugs (Refer to manufacturers instruction for proper installation)⁶

Wire Size	Burndy		Thomas	& Betts	llsco	
(AWG OR kcmil)	CU ONLY	CU / AL	CU ONLY	CU / AL	CU ONLY	CU / AL
6	YA6C-L Box YA6C	YA6CA1	54105 54905BE	61107 60107	CRB-6 CRB-6L	ACL-6
4	YA4C-L Box YA4C	YA4CA1	54106 54906BE	61112 60112	CRB-4 CRB-4L	ACL-4
2	YA2C-L2 Box YA2C	YA2CA5	54107	61116	CRA-2 CRB-2L	ACL-2
1	YA1C-L2 YA1C		54108 54947BE	61122	CRB-1-14 CRA-1L	
1/0				61130		

Accessories

Aux. Switch (1NO - 1NC)	HA161234	Compression Lug Neutral Barrier Kit	HCL623	Isolated Ground Lug Kit	HG261234
Aux. Switch (2NO - 2NC)	HA261234	Neutral	HN263	Wire Grip Kit (CU)	HLC63
Low Voltage Aux. Sw. (1NO - 1NC)	HA361234	Ground Lug Kit (Wire Range 14-4 AWG)	HG61234	Hub Kits	ECHS125/HS125 (1 1/4") ECHS150/HS150 (1 1/2") ECHS200/HS200 (2")

Replacement Parts

Line Base	HNB623	Wire Grip Kit (AI)	HL63	Handle / Handle Guard	HHD61234
Load Base		Mechanism		Door	DTNF323RDOOR

Protected by one or more of the following US Patents: 6,134,979, 6,356,460, 5,945,650, 5,990,439.

¹Use outer two poles.

⁵ When tightening or replacing connectors, refer to lug mounting torque in Terminal & Wire Information Table.

⁶ If compression lugs are used for the neutral, order compression lug neutral barrier kit **HCL623.**

Siemens Energy & Automation, Inc. Bellefontaine, Ohio 43311 U.S.A. http://www.sea.siemens.com/power
Assembled in Mexico

Pc. No. 504117J03 1203

Job will not be printed unless approved by customer.					
	corrected	•			
	OK to Prir correction	nt with ns as marked			
	OK to prin	nt			

Job will not be pri by customer.	inted unless approved				
Artwork By:	Date:	AUTHORIZED BY	DATE	PART NUMBER	REV
Proofer:	Date:		06/21/06	504117J03	16P