

CATALOG NUMBER

# ECMLK125

**electricCenter**  
ACCESSORIES

## Main Lug Kit 100A - 125A

Same As:

■ MLK125 ■ MLK125M



### MAIN LUG CONVERSION KIT INSTALLATION INSTRUCTIONS



#### **⚠ DANGER**

**Hazardous Voltage.**  
Will cause death, serious injury  
or substantial property damage.

Turn off power supplying this  
equipment before working inside.

#### **⚠ SAFETY INSTRUCTIONS**

**Note:** This instruction outlines the  
recommended installation procedure.  
To be used only where specified and  
required by catalog number on the  
load center label.

1. Turn off and lock out the power supplying the load center before working inside.
2. Remove 1/4-20 nuts from bus studs and remove main breaker.
3. Install lugs on bus studs as shown, fasten with 1/4-20 nuts (provided). Torque to 40-45 lb-ins.

